



## ADDENDUM TO THE CONTRACT

for the

### Downtown Waterfront Improvements Materials Procurement

Contract No. DH19-038

**ADDENDUM NO.:** Two

**CURRENT DEADLINE FOR BIDS:**  
January 15, 2019

**PREVIOUS ADDENDA:** One

**ISSUED BY:** City and Borough of Juneau  
Docks and Harbors  
155 South Seward Street  
Juneau, Alaska 99801

**PREVIOUS DEADLINE FOR BIDS:**  
January 15, 2019

**DATE ADDENDUM ISSUED:** January 7, 2019

The following items of the contract are modified as herein indicated. All other items remain the same. This addendum has been issued and is posted online. Please refer to the CBJ Docks and Harbors Department webpage at: [http://www.juneau.org/harbors/proposed\\_regulations.php](http://www.juneau.org/harbors/proposed_regulations.php).

#### **PROJECT MANUAL:**

Item No. 1 SECTION 02896 – STEEL PIPE PILES, Part 2- Products, 2.1.A Materials:

**Add** the following Paragraph:

- E. Steel Pipe Piles 24" diameter by 3/4" thick wall may be substituted with a 5/8" thick wall pipe if the steel material properties meet ASTM A572 Grade 60. All other requirements for pipe piles specified herein shall remain the same. Substituted steel pipe piles meeting these requirements shall be bid under Pay Item 2896.1.

By: \_\_\_\_\_

  
Carl Uchtyl, P/E.  
Port Director

Total number of pages contained within this Addendum: 1